



- Notes:
- LIGHTNING MONOPOLE POSITION INDICATIVE ONLY & SUBJECT TO A LIGHTNING PROTECTION STUDY.
 - A BORED WELL WILL BE LOCATED WITHIN THE COMPOUND FOR A POTABLE WATER SUPPLY TO THE BUILDINGS. LOCATION SHOWN ON DRAWINGS INDICATIVE ONLY
 - OIL SEPARATOR TO BE CLASS 1 FULL RETENTION SYSTEM.

- ASSOCIATED DRAWINGS:
- FOR CONTINUATION OF FOUL & SURFACE WATER DRAINAGE SEE DRAWING NO. QR-320201-P-000-068
 - FOR BUILDINGS DETAILS SEE DRAWING NO. QR-320201-P-000-074
QR-320201-P-000-075
QR-320201-P-000-076
QR-320201-P-000-077
QR-320201-P-000-078

0	15.04.13	ISSUED FOR PLANNING	PM	PK	JC
REV.	DATE	REVISION DESCRIPTION	DRN	VER	APP
PURPOSE OF ISSUE - PRELIMINARY UNLESS INDICATED					
TENDER	<input type="checkbox"/>	CLIENT APPROVAL	<input checked="" type="checkbox"/>	CONSTRUCTION	<input type="checkbox"/>
		AS-BUILT	<input type="checkbox"/>	REVISED	<input type="checkbox"/>
Client	OWENINNY POWER LTD.				
Project	WIND PROJECT AT OWENINNY, BELLACORICK, CO. MAYO				
Contract					
Drawing Title	OWENINNY WINDFARM PROPOSED 110kV STATION LAYOUT OF SUBSTATION 3				
Production Unit	CIVIL, BUILDING & ENVIRONMENTAL GROUP				
<p>Oweninny Power Ltd</p> <p>Oweninny Power Ltd, Stephen Court, 18-21 St. Stephen's Green, Dublin 2, Ireland Tel: +353 (0)1 7038000 Fax: +353 (0) 1 7038088 Email: oweninnypower@esbi.ie Web: www.oweninnywindfarm.ie Registered Office: as above Registered in Ireland No. 503730</p>					
DRAWN	PM	VERIFIED	PK	APPROVED	JC
CLIENT REF	No. of SHEETS		SIZE	REV	SCALE
	1		A1	0	1:250
DRAWING NUMBER					
QR320201-P-000-047					

COPYRIGHT © ESSI ENGINEERING & FACILITY MANAGEMENT LIMITED.
All rights reserved. No part of this work may be modified or reproduced or copied in any form or by any means, graphic, electronic or mechanical, including photocopying, recording, taping or information-and-retrieval system, or used for any purpose other than its designated purpose, without the written permission of ESSI Engineering & Facility Management Ltd.

While every effort has been made to ensure the accuracy of the information contained in the drawings, Oweninny Power Limited cannot be held responsible for errors or omissions.